



Jim Doyle, Governor
Mary P. Burke, Secretary

April 27, 2007

ASE FLO-RITE INC.
DAVID STRIGENZ & TOM STRIGENZ
2836F N BROOKFIELD RD
BROOKFIELD WI 53045

LSE SYSTEM AG
WERNER NAEF
SIHLEGGSTRESSE 23
WOLLERAU 8832
SWITZERLAND

Re: Description: PIPE RESTORATION / REPLACEMENT, ALTERNATE PLUMBING SYSTEM
Manufacturer: LSE SYSTEM AG
Product Name: LSE SYSTEM AG EPOXY HARTZ
Model Number(s): WATER PIPE RESTORATION SYSTEM
Product File No: 20070065

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an alternate approval to s. Comm 84.30 based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of April 2012.

This alternate approval is contingent upon compliance with the following stipulation(s):

- This system may be used for restoring copper, lead or steel water piping systems only.
- The restoration process must include the use of manufacturer's products, equipment, procedures as specified in LSE-System AG Restoration manual Version 10.2000.
- Equipment must be maintained in accordance with manufacturer's requirements at weekly, monthly and yearly intervals.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wisconsin.gov